



NOTES:

1. ALL TRENCH EXCAVATION AND COMPACTION SHALL BE IN ACCORDANCE WITH STANDARD SPECIFICATIONS.
2. CORPORATION STOP AND SERVICE PIPE SHALL MATCH SIZE OF METER.
3. METER LID SHALL BE MARKED "IRRIGATION".
4. IF PARK STRIP IS LESS THAN 3 FEET, THEN MOVE TO BEHIND SIDEWALK.
5. EACH SERVICE SHALL HAVE ITS OWN TAP. DO NOT COMBINE SERVICES TO REDUCE NUMBER OF TAPS.

IVINS CITY
55 N. Main Street
Ivins, Utah 84738
435-634-0689
435-674-5486 (fax)



rev. 07-2010

3/4" AND 1" IRRIGATION WATER CONNECTION

Standard
Drawing
I-01